

STI isolatable fuse-carriers:

Provide overload and short circuit protection
 Used in tertiary and industrial sectors
 Can be used with fuse link aM, gG (gl, gL) types.
 Complies with standard IEC 947.3.

Time Switch - IH/IHP

- IH mechanical time switch
 - IHP digital time switch

IC Light sensitive switch

Light sensitive switch closing of contact when brightness decrease and drop below the selected threshold. They control opening of a contact when brightness increase and rises above the selected threshold

Cầu chì cách ly STI :

Bảo vệ quá tải và ngắn mạch
 Được sử dụng trong các lĩnh vực công nghiệp.
 Được dùng với các ống chì loại aM, gG (gl-GL).
 Tuân theo tiêu chuẩn IEC 947.3.

Bộ đóng ngắt hẹn giờ

- IH bộ đóng ngắt hẹn giờ bằng cơ khí
 - IHP bộ đóng ngắt hẹn giờ bằng kỹ thuật số

IC Cảm biến ánh sáng

Công tắc cảm biến ánh sáng đóng tiếp điểm khi độ sáng giảm và xuống thấp hơn ngưỡng chọn. Và mở tiếp điểm khi độ sáng tăng và vượt qua ngưỡng chọn.



Unit price (incl.VAT) in VND

Acti 9 - STI isolatable fuse-carrier, 500V			
Type	Dimension(mm)	Reference	Unit Price
1P	10.3 x 38	A9N15636	119,900
1P+N	10.3 x 38	A9N15646	181,500
2P	10.3 x 38	A9N15651	239,800
3P	10.3 x 38	A9N15656	400,400
3P+N	10.3 x 38	A9N15658	415,800



CCT15850

Time switch, 230VAC							
Type	No. of channel	No of switching operations	Saving on mains cut off	Override Input	Rating (A)	Reference	Unit Price
24hrs and/ or 7days	1	56	6 years		16	CCT15850	3,928,100
	2	56	6 years		16	CCT15852	4,771,800
7days	1	84	6 years	1	16	CCT15851	6,812,300
	2	84	6 years	2	16	CCT15853	6,282,100
24hrs	1	48	200 hours		16	CCT15365	2,957,900
	1 set of 20 riders (5 each of red, green, white and yellow)					15341	89,100



CCT15365

IC light sensitive switches, 220/240VAC (included cell)				
Type	Adjustable brightness threshold	Type of cell	Reference	Unit Price
IC2000	2 to 200 lux	Switchboard cell	CCT15284	4,890,600
		Wall-mounted cell	CCT15368	6,395,400
Switch board cell	Spare photocells		15281	1,593,900
Wall mounted cell	Spare photocells		CCT15268	2,656,500

Example: Automatic controlling of bells, lighting: bells sounding the resumption and finish of work (channel 1), lighting of premises (channel 2).



IC2000

	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
Channel: 1 bell (20s pulse order)							
On	8h00	8h00	8h00	8h00	8h00	9h00	-
Duratinon	20s	20s	20s	20s	20s	20s	-
On	12h00	12h00	12h00	12h00	11h00	13h00	-
Duratinon	20s	20s	20s	20s	20s	20s	-
On	14h00	14h00	14h00	14h00	14h00	-	-
Duratinon	20s	20s	20s	20s	20s	20s	-
On	18h00	18h00	18h00	18h00	16h00	-	-
Duratinon	20s	20s	20s	20s	20s	20s	-
Channel 2: lighting (lached order)							
On	7h30	7h30	7 h 30	7h30	6h30	8h30	-
Off	18h30	18h30	18h30	18h30	17h30	13h30	-